



Edward Jones Branch Office #: Om	ana #00850				
Address: 4251 S 144th St	https://my.matterport.com/show/?m=1T3D4bvKDDX				
Matterport Link:		ow/ m=113D4bykDDx encegroup-my.sharepoint.com/:f:/p/katie_laird/Ep-E2qV0sYpEuUx0gt-			
Supplemental Photos:	nttps://trielawr	U110Br6pLdEdue33seTwBNb9UXQ?e=YdgYmE_			
Tenant Drawings:	https://thelawrencegroup-m	y.sharepoint.com/:f:/p/katie_laird/EkmgdZFFp3dOmEKAf8KxWpcB_Ky9uKhgwJtJB- lnUpjWcQ?e=HvF8rS_			
PREPARED BY:	Lawrence Group				
Surveyor Name:	Neal Fister				
Surveyor Phone Number:	636-448-0848				
Site Verification Date:	4/4/2024				
LANDLORD / BUILDING REPRESENTATIVE:	21 400 000 000				
Name: Maddie Graeve	Phone: 402-255-6527	Email: Maddie.Graeve@npdodge.com			
ENVIRONMENTAL CONCERNS	Notes	Action Items			
Are there any environmental concerns based on your observations?	NO				
Evidence of Water Intrusion	NO				
Suspected Visible Mold	NO				
Suspected Asbestos	NO				
Suspected Lead	NO				
Other					
BUILDING OVERVIEW	Notes	Action Items			
Number of levels/floors	1				
Proposed EDJ level/floor	1				
Total building SF					
SF of proposed EDJ space					
What is above our space?	roof				
Basement	NO				
Slab on Grade	YES				
Other	Notes	Asking Harris			
STRUCTURE	Notes	Action Items			
Construction Type					
Description of Construction (Wood, Steel, Masonry) Store Front Construction	steel structure/Masonry exterio				
Roof Structure	Bar Joist / Metal Deck				
Other	Dai Joist / Wetai Deck				
SIGNAGE	Notes	Action Items			
Is Exterior Signage an option?	YES	Action (cents			
Mounted on the building?	YES				
Monument sign?	UNKNOWN				
Pylon Sign?	UNKNOWN				
Window decals?	YES				
Is power available to the signs?	UNKNOWN				
Is the existing signage functioning?	N/A				
Overall condition of existing signage:					
FLOORS	Notes	Action Items			
Ceramic Tile	YES				
Concrete	NO				
Vinyl	YES	VCT in break room and data closet			
Carpet	YES				
Wood/Laminate	NO				
Other					
Existing Base / Trim Type	4" vinyl	4" wood base in offices			
WALLS	Notes	Action Items			
Tenant Separation Walls in Place	YES				
Tenant Separation Walls Sheetrocked to Deck	YES				
Tenant Separation Walls Sealed & Fire Rated to Deck	YES				
Tenant Separation Walls Insulated	YES				
Interior Partitions Extend Above Ceiling	YES				
Interior Partitions Load Bearing (excluding exterior walls)	NO				
Columns in the Tenant Suite	NO				
	9"-0" in main space	sill height 4' head height 7'-6" in back windows			
Window Heights throughout the space:					





Edward Jones Branch Office #: Oma	ha #06850	
Address:4251 S 144th St		
Matterport Link:	https://my.matterport.com/	
Supplemental Photos:	https://thela	wrencegroup-my.sharepoint.com/:f:/p/katie_laird/Ep-E2qV0sYpEuUx0gt- U11oBr6pLdEdue33seTwBNb9UXQ?e=YdgYmE
Other		Drive up teller window 40" sill, head height 6'-4"
CEILINGS	Notes	Action Items
Ceiling Type #1		
XXXX	2x2 tegular edge	
Ceiling Type #2		
XXXX		
Condition of Ceilings	GOOD	
Bottom of Joists from Finished Floor	13'-6"	
Bottom of Deck from Finished Floor	15'-0"	
Other		
LIGHTING	Notes	Action Items
Lighting Type #1	Notes	Action terms
Lighting Type #1	2x4 fluorescent	
Lighting Type #2	ZA4 Huorescent	
Lighting Type #2	fluorescent can lights	
Lighting Type #3	naorescent can lights	
LIBITUITS 19PC #3		
Lighting Type #4		
Lighting Type #4		
FIRE PROTECTION	Notes	Action Itoms
	Notes	Action Items
Sprinklered	NO	
Fire Alarm	YES	
DOORS	Notes	Action Items
Primary Entrance Door(s)	3'x7' full glass	
Condition	POOR	
Material	glass	
Size		
Hardware Type	push/pull	
Does the door hardware meet accessibility compliance?	YES	
Interior Door(s) Type 1		
Condition	GOOD	
Material	wood	
Size	3'-0"x 7'-0"	
Hardware Type	lever	
Does the door hardware meet accessibility compliance?	YES	
Secondary (Rear Egress) Door		
Condition		N/A
Material		
Size		
Hardware Type		
Does the door hardware meet accessibility compliance?		
ACCESSIBILITY	Notes	Action Items
Accessible Parking Stall	YES	
Accessible Load Zone	N/A	
Accessible Curb Ramp	YES	
Clear and Level Path of Travel to Entrance	YES	
Ramp outside of building	YES	
At Least One Accessible Entrance	YES	
Continuous accessible route starting in the parking lot and		
ending inside the front door of the building	YES	
Accessible Water Closet		
Is there a restroom in the space?	YES	
Is there a common restroom that serves the space?	NO	
Centerline of Toilet (16"-18")	YES	18-1/2"
Height of Toilet Seat (17"-19")	YES	
Flusher located on side away from nearest wall	YES	Auto flush
Space for 5' turning circle in restroom	YES	
For the toilet, is the 5' clear space from the side wall	YES	
·		
For the toilet, is there 4'-8" clear space from the rear wall	YES	





Address:4251 S 144th St						
Matterport Link:	https://my.matterport.com/show/?m=1T3D4bvKDDX					
Supplemental Photos:		ny.sharepoint.com/:f:/p/katie_laird/Ep-E2qV0sYpEuUx0gt- ppLdEdue33seTwBNb9UXQ?e=YdgYmE				
s the common restroom for a single occupant or have		//A				
talls?		'' [^]				
s the toilet wall hung or floor mounted?	Floor					
Rear Grab Bar (36")	<u> </u>	2"				
Гор of rear grab bar height (33"-36")	YES					
Does the rear grab bar extend 12" from the CL of the	NO					
oilet to the wall and at least 24" in the other direction?						
1.5" in diameter	YES					
1.5" clear space around the grab bar	YES					
Horizontal grab bar (42") on side wall	YES					
Horizontal grab bar is at most 12" from rear wall	YES					
Top of horizontal grab bar height (33"-36")	YES					
1.5" in diameter	YES					
1.5" clear space around the grab bar	YES					
/ertical Bar (18")	NO					
Toilet Paper Dispenser						
Type of toilet paper dispenser:	single roll					
Dispenser height from floor (max. 48")	YES					
Dispenser at least 24" from rear wall & at most 42"	YES					
Accessible Lavatory						
Top edge of sink/lavatory 34" or less from floor	YES					
Bottom edge of sink/lavatory 27" or higher from floor	YES					
Knee clearance of 8" or more at 27" or higher from the floor	YES					
Centerline of Sink (15" Min.)	YES					
Clear Floor Area (30" x 48")	YES					
Insulated Drain Pipe	YES					
Other						
Additional Items						
Is there a mirror above the sink	YES					
Bottom edge of mirror 40" or less from floor	YES					
s there a paper towel dispenser		uto				
Paper towel dispenser is between 15"-48" from the floor						
	YES					
Clear floor space of 30"x48" around dispenser	YES					
s there an air-powered hand dryer	NO					
Height of light switch between 15"-48" from floor	YES					
Other						
SYSTEMS						
Is the space to be subdivided?	NO					
Do electrical or HVAC need to be divided or combined?	UNKNOWN					
WATER						
Water Heater: Make / Model# / Size		bove ceiling of womens restroon also serves break room				
Hot Water Functioning?	YES					
Service Sink?	NO					
Nater Fountains?	NO					
DEMARC						
Phone Service	YES					
ocation of telephone back board	In Teller area					
Location of main point of entry on the exterior of the	unknown					
uilding:						
Photo of DEMARC location	YES					
ELECTRICAL SYSTEM	Notes A	action Items				
Electrical Meters						
Meter#:	unknown					
ocation of Meter:	back side of building					
Electrical Panel #A						
.20 amp 208 v						
Electrical Panel #B						
NATURAL GAS	Notes A	action Items				





Address:4251 S 144th St		
Matterport Link:	https://my.matterport.com/show/?m=1T3D4bvKDDX	
Supplemental Photos:	https://thelawrencegroup-my.sharepoint.com/:fr/p/katie_laird/Ep-E2qV0sYpEuUx0gt- U110Br6pLdEdue33seTwBNb9UXQ?e=YdgYmE	
Gas Service to Tenant Suite	YES	
Meter #	unknown	
Location of Meter	Back side of building	
Other		
HVAC SYSTEM	Notes Action Items	
HVAC Power on at Time of Survey	YES	
Functioning Heat	YES	
Functioning AC	YES	
Heating Source	ELECTRIC	
System Type	RTU	
HVAC unit condition	GOOD	
Duct Distribution complete	YES	
Condition of duct work:	GOOD	
At least one supply & one return in each room/open space?	YES	
Separate from other tenants?	YES	
HVAC #1		
Model #	See pictures for RTU's	
HVAC #2		
Model #		
HVAC #3		
Model #		
Existing thermostat	YES	
Number of thermostats	6	
Exhaust fan in restroom	YES	